

# Energy Performance Certificate

## Non-Domestic Building

Voluntary EPC for GP360DH Mobile Welfare Unit

Certificate Reference Number:  
9000-3002-0000-0000-6091



This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Government's website [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd).

### Energy Performance Asset Rating

More energy efficient



Net zero CO<sub>2</sub> emissions

**A** 0-25

**B** 26-50

**C** 51-75

**D** 76-100

**E** 101-125

**F** 126-150

**G** Over 150

73

This is how energy efficient the building is.

Less energy efficient

### Technical information

Main heating fuel:	Oil
Building environment:	Heating and Natural Ventilation
Total useful floor area (m <sup>2</sup> ):	7
Building complexity (NOS level):	3

### Benchmarks

Buildings similar to this one could have ratings as follows:

**40** If newly built

**61** If typical of the existing stock